



Amy G. Rabinowitz
Counsel

November 20, 2002

Mary L. Cottrell, Secretary
Department of Telecommunications and Energy
One South Station
Boston, MA 02110

Re: Douglass v. Massachusetts Electric Company, D.T.E. 02-AD-3

Dear Secretary Cottrell:

I am enclosing Massachusetts Electric Company's responses to the Department's information requests in the above-captioned docket.

Very truly yours,

Amy G. Rabinowitz

cc: George Douglass

25 Research Drive
Westborough, MA 01582-0099
Phone 508.389.2975
Fax: 508.389.2463
amy.rabinowitz@us.ngrid.com

Massachusetts Electric Company
D.T.E. 02-AD-3
Department's First Set of Information Requests

D.T.E. – MECO-1-1

Request:

Please provide the maintenance history for meter 098650891.

Response:

The meter, serial # 098650891 was purchased in 1999 and installed on December 8, 1999 at 270 Broadmeadow Road, Marlboro, MA, with an initial reading of 0.

Attached is the meter panel for the meter, marked up to identify the pertinent fields. The meters are tested and calibrated by the manufacturer prior to shipment.

There is no maintenance history for this meter. The Company had no indication that the meter was not performing correctly, either from sample tests performed regularly on this type of meter or the actual meter itself. On the contrary, the meter was performing correctly. See the response to D.T.E. – MECO 1-2 and D.T.E. –MECO 1-3.

The meter was sealed at the time of installation and was still sealed when the meter worker tested it on December 28, 2001.

Prepared by or under the supervision of: Mark Sorgman

04/25/2002 - 14:40:02

270 BROADMEADOW RD APT: TR-PK LOT 39A MARLBOROUGH MA 01752
(508) 7865886 ID: SORGMA

Meter Selection			
098650891			
Meter Information			
Meter #:	098650891	Meter Data:	0997M01436
Meter Status:	ACTIVE	Type Measurement:	KWH
Ring Type:	STANDARD	Mfr. Type:	0000J5S
Max. Demand Scale:	000.0	Pot Lights:	
Meter Location:	OUTSIDE	Add Meter:	0
# of Meters:	1	Status Date:	12/08/99
Constant:	1	ERT ID:	
ERT TYPE:		BILLABLE	
Dial Sets		Miscellaneous Info	
# of Dialsets:	1	Engineering Code:	1386001499
Rate	# of Dials	Units	High Voltage Disc:
Dialset 1:	R1A0	5	KWH
Dialset 2:			
Dialset 3:			
CMT ID:		Battery Year:	
Program Version:		Program Year:	
Digital Type:		Meter Version:	
Ownership Code:	0	Probe Code:	N
Close			

Purchased
Tested in 2001
meter type

Massachusetts Electric Company
D.T.E. 02-AD-3
Department's First Set of Information Requests

D.T.E. – MECO-1-2

Request:

Has Massachusetts Electric Company ever performed a meter test on meter 098650891 since September 19, 2001? If so, please provide the results and all work papers from meter tests performed on meter 098650891 by Massachusetts Electric Company since September 19, 2001.

Response:

Yes, meter 098650891 was tested on December 28, 2001. The results of the test are:

Full Load: 100.8%
Light Load: 99.84%
Reading: 52535

Copies of the trouble order requesting the meter test and the meter test record are attached.

The reading at the time of the test supports the readings used in prior billings.

Prepared by or under the supervision of: Mark Sorgman

TROUBLE ORDER

12/03/01

INQUIRY OFFICE SOUTHEAST
PLEASE ROUTE TO

14.07.24

OPERATOR I.D. QUEZA

270 BROADMEADOW

RD MARLBOROUGH TR-PK L 39A

33 33FB0024 12/05/01

DOUGLASS

GEORGE

508 7865886

18124 61720 00 004 17 DAMARIS

QUEZA 12/03/01 14:07

METER DEPT

REMARKS: PLSE TEST MTR

INSTRS:

SERVICE TYPE: UG

ENG CODE: 1386001499

SUPPLY NO: 0310W0003DL

METER #: 098650891

LOC: OUTS

RATE: R1A0

MEDICAL: NONE

MTR DATA: 997M99A36

CONST: 1

LOOP CK: - NONE


RING TYPE: 0

DIALSET1:

DATE	RC	USE
111901	3	4910
111901	1	47056
101901	2	1695
091901	3	42146
091901	1	40451

FIELD REMARKS:

FL 100.08 LL 99.84

098650891 61720 05 997M99A36
REMARKS 12/03/01include
acct
ind

1 of 2

[illegible]

Massachusetts Electric Company
D.T.E. 02-AD-3
Department's First Set of Information Requests

D.T.E. – MECO-1-3

Request:

Has any other company, state or federal agency ever performed a meter test on meter 098650891 since September 19, 2001? If so, please identify the entity that tested the meter, when it was tested, and provide a copy of the findings along with any other documentation that supports those findings.

Response:

Yes, meter 098650891 was tested by the Department of Telecommunications and Energy on February 21, 2002. The results of the test are:

Full Load: 100.64%
Light Load: 100.27%
Reading: 57186

The Company received these results from the Department of Telecommunications and Energy by e-mail. A copy of the e-mail is attached.

The reading at the time of the test supports the readings used in prior billings and the read taken at the time of the December 28, 2001 meter test.

Prepared by or under the supervision of: Mark Sorgman

11/14/2002

Sorgman, Mark

From: OToole, Christine (DPU) [Christine.Otoole@state.ma.us]
Sent: Tuesday, November 12, 2002 4:01 PM
To: Mark.sorgman@us.ngrid.com
Subject: the douglass case

Mark:

The state meter test results for the Douglass case out of Marlborough:

Meter tested 2/21/02.

Results: Full load = 100.64 %

Light load = 100.27%

Actual read on 2/21/02 57186

Virgil Glenn tested the meter for the State. He usually gives the report to Ian McColgin and Ian puts the info into the case. In this case, the investigator put the result in the notes in the case. If you need anything else let me know.

Chris O'Toole
617-305-3648